

Havant Borough Council

The Town and Country Planning Act 1990

Consultation on Planning Application

From : Executive Head of Planning and Built Environment

To: Building Control

DC Case Officer Mrs B Crawford Ext: 9244 6514

Date: 19 October 2012

Application No. APP/12/01066

Site Address: 188 Cherry Tree Avenue, Waterlooville, PO8 8AX

Proposed Development: Rear conservatory.

I attach a copy of the above application that has been received under the Town and Country Planning Acts.

Any views you should wish to make should be returned to me together with the application papers no later than 02 November 2012.



Mr Chris Murray
Service Manager (Planning Development)

From: Building Control

The application has been examined under the following areas where Building Regulations may impact on the planning application. In achieving Building Regulation compliance there may be a number of design solutions available and until a Building Regulations submission has been made it is not always possible to advise what, if any, changes may be required to the design.

The following areas have been considered:

Fire Brigade Access† Solid Waste Storage† Glazing (Positions, quantities, cleaning)†

Siting of building/structure† Building over public sewers† ✓ Flues† Other†

Please note no observations have been made in respect of disabled access. The DC Case Officer should discuss any access concerns with Building Control at the Access Surgery following assessment of the scheme using the access check sheet.

Observations:

Although the building is exempt from Building Regs, the owner should consult with Southern Water. The extension is built over a public sewer and Southern Water may want a specific design for the foundations, or at worst, refuse building over it entirely

Signed: 

Dated: 23/10/12

Informative