



Atkins Limited
Anglo St James House
39A Southgate Street
Winchester
Hampshire SO23 9EH

Telephone +44 (0)1962 858688
Fax +44 (0)1962 810296

winchester.enquiries@atkinsglobal.com
www.atkinsglobal.com

Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your Ref: APP/13/00113

Our Ref: PLAN-002516

12/03/2013

Proposal: Extension to rear of existing performing arts building to create dedicated dance studio and alterations to existing building to provide additional teaching space and support facilities.

**Site: The Crookhorn Community School, Stakes Hill Road, Waterlooville, PO7 5UD.
APP/13/00113**

Dear Sir,

Thank you for your letter of 20/02/2013.

Southern Water requires a formal application for any new connection to the public foul sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development, please contact Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (Tel 01962 858688), or www.southernwater.co.uk"

Our initial investigations show that there is currently inadequate capacity in the local network to provide surface water disposal to service the proposed development. The proposed development would increase flows to the public sewerage system, and any existing properties and land may be subject to a greater risk of flooding as a result.

We advise that applicant investigates alternative means for surface water disposal, considering the following options:

Discharge to an available watercourse

Discharge to soakaways

Alternatively;

If the existing development discharges surface water to the existing surface water system, then a discharge from the site may be permitted. If the applicant wishes to investigate this option, the applicant will be required to provide a topographical site survey and/or a CCTV survey showing the existing connection points, pipe sizes, gradients and calculations confirming the proposed flows will be no greater than the existing flows received by the sewer. Any excess surface water should be attenuated and stored on site. Where flow attenuation is proposed and the sewerage in question is to be offered for adoption, the sewerage undertaker should be involved in discussions with all relevant parties to agree the ownership/responsibility for the facility.


Southern Water requires a formal application for a connection to the public sewer. The applicant is advised to contact Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (Tel 01962 858688), or www.southernwater.co.uk"

This initial assessment does not prejudice any future assessment or commit to any adoption agreements under Section 104 of the Water Industry Act 1991.

Southern Water's current sewerage records do not show any public sewers to be crossing the above site. However, due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (Tel 01962 858688).

Yours faithfully,


Developer Services