

## Michelle Houghton

---

**From:** Aaron Wright  
**Sent:** 29 May 2013 14:58  
**To:** bst shared  
**Subject:** FW: 26 Summerhill Road

**Importance:** High

Please add to meridio and web -

APP/13/00318

APP/13/00348

---

**From:** Jamie Gargett  
**Sent:** 29 May 2013 14:54  
**To:** Aaron Wright  
**Subject:** 26 Summerhill Road  
**Importance:** High

### 26 Summerhill Road

Aaron In respect of the above application I have the following comments:

Low quality tree removal is required to facilitate this project. (x2 C cat Oaks - both subject to a TPO) The supporting arboricultural evidence is comprehensive and provided that the methodology prescribed in this MS & TPP report is strictly adhered to (inclusive of site monitoring works) the other trees will survive the development unscathed and to continue to grow on safely and healthily in the future.

However I would like to see mitigation planting for the loss of the two oaks with a two for one ratio. The replacement Oaks should be 2m in height container grown trees at the time of replant. I would also like sight of the landscaping scheme prior to any conditions being approved.

Therefore I have no objections to this scheme in arboricultural terms.

Thanks  
J

Jamie Gargett  
Arboriculturalist  
Planning & Built Environment  
Havant Borough Council  
Public Service Plaza  
Havant  
PO9 2AX  
023 9244 6525  
[jamie.gargett@havant.gov.uk](mailto:jamie.gargett@havant.gov.uk)