

Havant Borough Council

The Town and Country Planning Act 1990

Consultation on Planning Application

From : Executive Head of Planning and Built Environment

To: Building Control

DC Case Officer Mrs R Hebden Ext: 9244 6518

Date: 12 September 2012

Application No. APP/12/00917

Site Address: Land r/o 82B and 86-90 Bedhampton Road and 2 Lester Avenue

Proposed Development: Construction of 1No. 3 bed bungalow with integral garage, parking and landscaping and utilising existing access from Bedhampton Road.

I attach a copy of the above application that has been received under the Town and Country Planning Acts.

Any views you should wish to make should be returned to me together with the application papers no later than 26 September 2012.

C. D Murray

Mr Chris Murray
Service Manager (Planning Development)

From: Building Control

The application has been examined under the following areas where Building Regulations may impact on the planning application. In achieving Building Regulation compliance there may be a number of design solutions available and until a Building Regulations submission has been made it is not always possible to advise what, if any, changes may be required to the design.

The following areas have been considered:

Fire Brigade Access: ✓ Solid Waste Storage: ✓ Glazing (Positions, quantities, cleaning):

Siting of building/structure: Building over public sewers: ✓ Flues: Other:

Please note no observations have been made in respect of disabled access. The DC Case Officer should discuss any access concerns with Building Control at the Access Surgery following assessment of the scheme using the access check sheet.

Observations:

- 1) Fire brigade access will not comply with B'regs and compensatory features will be required. Requirement B5
- 2) The travel distance for solid waste storage does not comply with Requirement H6

Signed:

BT

Dated:

27/9/12

↓
double deck implant's.

spinkler system /
turning circle.