


Mr. Darren Thrussell
MJA Consulting
58-62
Ock Street
Abingdon
Oxon
OX14 5BZ



Atkins Limited
Anglo St James House
39A Southgate Street
Winchester
Hampshire SO23 9EH

Telephone +44 (0)1962 858688
Fax +44 (0)1962 810296

winchester.enquiries@atkinsglobal.com
www.atkinsglobal.com

07/03/2011

Our Ref: SWS-HANTS-CC-000770

RE: Capacity check application for Denvilles/Manor Farm, Fifth Avenue, Glenleigh Park Road, Havant, Hampshire PO9 2PH

Dear Mr. Thrussell,

We have completed the capacity check for the above development site and the results are as follows:-

Foul capacity check:

There is currently adequate capacity within the foul sewerage network to accommodate a foul flow of 4.8 l/s at manhole reference SU72069600. Please note that no surface water flows (existing or proposed) can be accommodated within the foul sewerage system.

Surface water capacity check:

There is currently inadequate capacity in the local surface water network to accommodate a proposed surface water flow of 200 l/s at manhole reference SU72069651.

The surface water should be disposed of using alternative means such as soakways, or any local drainage watercourses, subject to all interested parties approval

Where capacity is limited/restricted, agreement should be sought if you including any highway drainage within your proposals as Southern Water is not obligated to accept highway flows.

Before any connections are made to foul and surface sewerage network, an application form needs to be completed and approved by Southern Water Services.

Should you require any further information, please contact us at the above mentioned phone number or address.

Yours faithfully

A handwritten signature in blue ink, appearing to be 'MJA'.

Network Development

Please note: -

The information provided above does not grant approval for any designs/drawings submitted for the capacity analysis. The results quoted above are only valid for 12 months from the date of issue of this letter.