

Memorandum

To: Miles Rankin – HCC
From: Steve Gosling – 24 Acoustics Ltd
Date: 8th November 2012
Job: 4057, South Downs College
Ref: Review of Acoustic Barrier

24 Acoustics has reviewed the noise impact of the proposal which excludes a noise barrier at the location of the pitch entrance gates at the south eastern boundary. It is understood that this requirement arose to allow the gates to open.

24 Acoustics has reviewed the noise implications of this proposal and can confirm that the net effect in overall terms is an increase of 0.5 dB at the nearest affected property which would be significantly below the threshold of perception (between two noise levels). It is therefore considered that this proposal is acceptable.