

PROPOSED RESIDENTIAL DEVELOPMENT
LAND SOUTH OF, LOWER ROAD, AND WEST OF OLD MANOR FARM,
HAVANT,
HAMPSHIRE

SUDS MANAGEMENT & MAINTENANCE PLAN

BARGATE HOMES LTD

REVISION B
JULY 2024

REF: SS/21/0433/6430



DOCUMENT CONTROL RECORD

Document Issue:

Rev	Date	Issue Status	Prepared by	Checked by
-	24.09.21	First Issue	S. Smith	C. Pendle
A	22.07.24	Updated to current design	S. Smith	C. Pendle
B	30.07.24	Updated to client's comments	S. Smith	C. Pendle

References:

The SUDS manual – CIRIA C753 (2015) ISBN 9780-86017-760-9

National Planning Policy Framework (NPPF) – Communities and Local Government
Technical Guidance - Flood Risk & Coastal Change (March 2012)



1 Introduction

- 1.1 This document sets out the principles for the long term management and maintenance of the proposed surface water Sustainable Drainage Systems (SuDS) installed at the residential development at land adjacent to Lower Road, Bedhampton.
- 1.2 The purpose of this document is to set out the basis of the development SuDS Maintenance Plan and to ensure that the adopting management company is entrusted with a robust inspection and maintenance programme, ensuring the optimum operation of the surface water drainage network is continually maintained for the lifetime of the development and to prevent the increased risk of flooding both on and off site in accordance with the National Planning Policy Framework (NPPF).
- 1.3 The activities listed in this document are generic to the relative SuDS types and represent the minimum maintenance and inspection requirements, however additional tasks or varied maintenance frequency may be instructed by the maintenance company as required. Specific maintenance needs of the SuDS elements should be monitored and maintenance schedules adjusted to suit requirements.
- 1.4 The installed SuDS system at this development are the initial responsibility of Bargate Homes. Following installation and after an initial period (TBC) of operation, all SuDS are to be transferred to an appointed Management Company. An agreement shall be set up by Bargate Homes, who shall confirm in writing to the Principle Planning Officer at Hampshire County Council when the maintenance agreement is completed and is operative.
- 1.5 The Management Company will then be responsible for maintaining the surface water system including all SuDS in perpetuity. All property owners should be advised that an annual management fee will need to be paid to the management company for this service.
- 1.6 All those responsible for maintenance should follow relevant Health and Safety legislation (Health and Safety at Work Regulations, 1999) for all activities listed within this report including lone working, if relevant) and risk assessments should always be undertaken.
- 1.7 Any contractor employed by the Management Company shall carry out periodic maintenance of all such SuDS in accordance with the schedules listed in this report. Inspection checks shall be carried out by a qualified and competent person, at the minimum intervals listed within the schedules and the appropriate work carried out.
- 1.8 This report is to read in conjunction with MJA drawing '*001 Drainage Strategy*' for the location of all SuDS elements present within the development. Reference should also be made to the detailed landscape proposals for the proposed treatment / maintenance regime for all landscape features. The operations contained within this plan shall (where feasible) be in conjunction with routine grounds maintenance operations to the surrounding landscape.

2 SuDS Layout & Design

- 2.1 The storm water drainage strategy for the proposed development is to utilise a range of SuDS features to attenuate all surface water runoff from impermeable areas, with a restricted discharge via a flow control into ditch via overland flow.
- 2.2 The proposed storm water system consists of the following drainage and SuDS components:
- Attenuation Basin
 - Storm water pipe work and road gullies
 - Permeable block paving
 - Flow control chambers
 - Overland Overflow Outfall Pond
- 2.3 There are three categories of maintenance activities referred to in this report:
- **Regular maintenance** (including inspections and monitoring).
Consists of basic tasks done on a frequent and predictable schedule, including vegetation management, litter and debris removal, and inspections.
 - **Occasional maintenance**
Comprises tasks that are likely to be required periodically, but on a much less frequent and predictable basis than the routine tasks (sediment removal is an example).
 - **Remedial maintenance**
Comprises intermittent tasks that may be required to rectify faults associated with the system, although the likelihood of faults can be minimised by good design.
Where remedial work is found to be necessary, it is likely to be due to site-specific characteristics or unforeseen events, and as such timings are difficult to predict.
- 2.4 It is also important that measures are taken to protect and ensure continued operation of drainage features during the construction phase. All road gullies will be blocked until the site is complete. Mesh will be placed over the outfalls and swales to prevent construction silts clogging up the drainage system and basins.

3 SUDS Management & Maintenance

3.1 Storm water pipe work and road gullies

- 3.2 The key maintenance requirement for the upstream surface water drainage system includes the removal of sediments and debris from the system as required.
- 3.3 All storm water pipe work should be visually inspected a minimum of monthly for the first three months after installation and then a minimum of once year. As road gullies are the first on the treatment train and susceptible to higher silt loadings, these will need to be inspected a minimum of monthly for the first three months after installation and then a minimum of every four months.
- 3.4 During this inspection identify any gully pots or pipes that require remedial maintenance such removal of sediment, debris, leaves and litter as required. This involves the removal all protective covers and grids and the cleaning out of channels or gully pots by hand or with suitable jetting equipment.
- 3.5 During the inspections the general operation and structural integrity of all components should be recorded and repaired as required.

3.6 Flow Control Chamber

- 3.7 The key maintenance requirement for the flow control chamber will be the inspection of the units for blockages of the vortex flow control unit and silt removal from sump of chamber.
- 3.8 The hydraulic vortex flow control unit has no moving parts and is self-activating, requiring minimal maintenance. After initial installation, it is recommended that the unit be inspected monthly for three months.
- 3.9 Thereafter the manhole chamber and control device should be inspected at least every six months to verify the condition and operation of the unit and check for blockages within the inlet of the chamber and of the flow control device. During these inspections, accumulated silts should be removed and the sump cleaned out using a conventional sump vacuum cleaner. Flow Controls are fitted with a pivoting by-pass door, which allows the manhole chamber to be drained down should blockages occur.

3.10 Overland Overflow Outfall Pond and Swales

- 3.11 The outfall pond and swales should be visually inspected a minimum of monthly for the first three months after installation and then a minimum of twice a year. Accumulated sediments, debris and any overgrown vegetative material should be removed. Any reeds should be maintained in line with the landscape management plan.

3.12 Attenuation Basins

Key Maintenance Requirements:

- Litter/trash removal
- Inlet/outlet headwall inspection and cleaning
- Vegetation management
- Sediment monitoring and removal when required

- 3.13 Regular inspection and maintenance is important for the effective operation of the attenuation basin. The basin will be subject to a routine monitoring and maintenance schedule as part of the general site management. This will be carried out at intervals detailed below, and shall comprise of the following operations:
Collection and removal of all litter/large debris from the attenuation pond, inlets, outflows, and water margins once a month.
Monthly inspection of the attenuation ponds to check the following, and repair as necessary:
1. Any failure in the operation of the inlet and outlet headwalls unless adopted by others in which case they will be notified of any observed defect.
 2. Any damage or erosion to the perimeter edges and slopes of the attenuation ponds.
- 3.14 Please see landscape management plan for further details of planting and management.
- 3.15 An annual check carried out by a suitably qualified person, to assess the condition and operation of the attenuation basin inlet and outflow, and the accumulation of silt/sediment.
- 3.16 A record of maintenance visits and remedial operations shall be maintained.
- 3.17 **Desilting of Attenuation Basins**
In addition to regular routine items, SuDS maintenance will be carried out which may include de-silting the attenuation ponds, usually on a 10-15 year cycle depending on the on-going silt level checking. This can be an intrusive operation when carried out within housing areas and prior to any planned desilting or dredging, consultation will be undertaken with both the LLFA and the Environment Agency.
- 3.18 Before any desilting operations are carried out, residents and members of the public in the general area will be informed and those in the immediate vicinity will be notified in writing well in advance of commencement of works.
- 3.19 The desilting work will be carried out under the supervision of consulting engineers and to a pre-agreed method statement. Such a method statement should be submitted in writing to the local authority and agreed in advance of the commencement of the works.
- 3.20 Prior to desilting works commencing, a suitably qualified ecologist shall be appointed to undertake an assessment of the ecological interest within the pond and its margins. In the event that the attenuation ponds develop particular ecological interest, then careful consideration will be given to the timing of this operation.

3.21 Permeable Block Paving

- 3.22 Note: Loose materials such as sand, cement soil or other loose substances should not be stored directly on top of the permeable blocks without the use of an impenetrable sheet.
- 3.23 To ensure the continual optimal performance of the permeable paving, it is recommended that the following maintenance should be carried out. The following guidelines are offered as an initial regime, but maybe either increased or decreased by the management company depending on the local environment and any external contributing factors.
- 3.24 Permeable pavements should be visually inspected a minimum of monthly for the first three months after installation and then a minimum of three times a year, preferably during and after heavy rainfall to check effective operation and identify areas of ponding. These inspections should occur close to the end of winter (March), mid-summer (July) and after the autumn (November).
- 3.25 During this inspection identify any areas that require remedial maintenance such as topping up of jointing grit or removal of vegetation, weeds, silts and sediments that may be clogging the joints between the blocks. Small areas such as driveways can be swept with a hand bristle broom, for larger areas such as parking courts a lorry mounted rotary brush and vacuum sweeper device can be used. Weeds can be removed from the surface through the controlled application of proprietary non-persistent contact herbicides. Those containing Glyphosate are the most suitable.
- 3.26 Care should be taken to ensure that only the detritus is removed from the joints and avoid removal of the jointing material. If required, joints should be replenished with aggregate material to lip of paver using specific 6-2mm single size grit using a stiff brush to sweep the material in ensuring joints are filled. Do not replace the jointing grit with sand as this will stop the permeable system from working.
- 3.27 For winter maintenance, the controlled use of de-icing may be used without causing significant detrimental effects towards the permeable pavements performance. When used carefully, the use of these chlorides will not result in an increase in the chloride levels in the local ground.
- 3.28 Contamination of the permeable block paving from routine landscape maintenance such as grass clippings from mowing, hedge trimming, mulching plant beds etc. should be prevented. If contamination occurs the debris should be immediately swept, collected and removed by the homeowner or landscape operative.
- 3.29 Depending on the amount of usage and the environment the permeable pavement has received and been exposed to, the sub base laying course material including geotextile membranes/ grids may require either replacement or cleaning after a 25 to 30 year period. This would be evident if the infiltration rate of the paving became prolonged, allowing ponding to develop. Should this occur, the uplifting and cleaning or replacing of the laying course maybe considered. The laying course material, jointing and blocks can be reused once cleaned, minimising costs.

- 3.30 Replacement sub-base material to be used should be a clean 4/20mm coarse graded aggregate to BS EN13242:2002. Jointing material between the blocks should be 6-2mm single size grit to the joints. Refer to MJA Consulting construction detail drawings for type of geotextile membrane/ geogrids to be used.
- 3.31 Materials removed from the voids or the layers below the surface may contain heavy metals and hydrocarbons and may need to be disposed of as controlled waste. Sediment testing should be carried out before disposal to confirm its classification and appropriate disposal methods.

Permeable Paving Operation and Maintenance Requirements

Maintenance schedule	Required action	Frequency
Regular maintenance	Brushing and vacuuming.	Three times/year at end of winter, mid-summer, after autumn leaf fall, or as required based on site-specific observations of clogging or manufacturers' recommendations.
Occasional maintenance	Stabilise and mow contributing and adjacent areas.	As required.
	Removal of weed.	As required.
Remedial actions	Remediate any landscaping which, through vegetation maintenance or soil slip, has been raised to within 50 mm of the level of the paving.	As required.
	Remedial work to any depressions, rutting and cracked or broken blocks considered detrimental to the structural performance or a hazard to users.	As required.
	Rehabilitation of surface and upper sub-structure.	As required (if infiltration performance is reduced as a result of significant clogging).
Monitoring	Initial inspection.	Monthly for 3 months after installation
	Inspect for evidence of poor operation and/or weed growth. If required take remedial action.	3-monthly, 48 h after large storms.
	Inspect silt accumulation rates and establish appropriate brushing frequencies.	Annually.
	Monitor inspection chambers.	Annually.

4 Contact Information

For further information on the management and maintenance of SuDS on the development please contact:

MJA Consulting
Ipsum Court
24 The Quadrant
Abingdon Science Park
Oxfordshire
OX14 3YS

Tel: 01235 555173
Email: mail@mjaconsulting.co.uk

MJA CONSULTING
Civil & Structural Engineers

Monarch House • Abingdon Science Park
Barton Lane • Abingdon • Oxon • OX14 3NB
Tel: (01235) 555173 • www.mjaconsulting.co.uk