



Re: APP/20/00875 - DOC 14 - Water efficiency

From Thomas, Darren <Darren.Thomas@havant.gov.uk>

Date Mon 2025-09-15 1:49 PM

To Riley, Robert <Robert.Riley@havant.gov.uk>

Robert

The calculations show that flats 1 and 4 achieve 108.8 l/p/d and flats 2,3,5 and 6 achieve 104.4 l/p/d which is better than the allowed 110 l/p/d.

Regards

Darren Thomas

BSc (Hons) C.Build E MCABE

Principal Building Control Surveyor | T: 02392 446643 |

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

East Hampshire District Council

If you require a Building Control inspection and have a current Building Regulation application please phone 02392 446 571 by 4pm on the day before you want the inspection.

www.havant.gov.uk

www.facebook.com/havantboroughcouncil

www.twitter.com/havantborough

www.easthants.gov.uk

www.facebook.com/easthampshiredistrictcouncil

www.twitter.com/easthantsdc

Your privacy matters. Go to www.havant.gov.uk/privacy-policy.

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.