

Thank you for consulting Environmental Health (pollution) regarding the above application.

The proposed development site may be exposed to road traffic noise from Philip Road and Stakes Hill Road and plant / equipment or activities associated with The Fox and Hounds Public House.

Noise – further information required

No information has been provided assessing the potential noise impact from road traffic or nearby commercial uses including deliveries and plant / equipment.

I therefore recommend that in order for this section to make an informed comment the applicant should be requested to provide further information assessing the noise impact of the external noise sources on the proposed residential accommodation. The report should include, if appropriate, measures to be taken to mitigate excess noise impact.

The report should be prepared by a person with appropriate acoustic qualifications and should be with full regard to all relevant guidance including BS8233:2014 - Guidance on Sound Insulation and Noise Reduction for Buildings and BS4142:2014 Methods for rating and assessing industrial and commercial sound.

Sincerely,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX