

From: coastal.planning <coastal.planning@havant.gov.uk>

Sent: 16 September 2025 15:09

To: Miszewska, Arleta <Arleta.Miszewska@havant.gov.uk>; Weaver, Steve <Steve.Weaver@havant.gov.uk>

Subject: Coastal Partners Consultation Response APP/21/01350 Land north of Oysters, Station Road, Hayling Island

Local Planning Authority: Havant Borough Council

Site Address: Land north of Oysters, Station Road, Hayling Island

Proposed Development: Outline application for erection of up to 29 dwelling units and associated highway works with all other matters reserved

Reference: APP/21/01350

Response:

Thank you for re-consulting Coastal Partners on the above application.

Site Specific Flood Risk Assessment (FRA)

The applicant submitted a site-specific FRA to support the applicant, and Coastal Partners commented on 9 November 2022, concluding that the FRA sufficiently outlined how tidal flood risk at the site will be mitigated. We can confirm that our comments regarding the FRA remain valid and do not require an update.

Flood Risk to Hayling Island

The LPA should note that in July 2025 the Environment Agency approved Coastal Partner's Hayling Island Coastal Management Strategy, following approval by Havant Borough Council. This strategy reviews in detail the flood and erosion risk to the whole of the island's coastline, the condition of the existing defences and the changes that are expected as a result of climate change. Preferred options for addressing changing risks have been identified for each 'Option Development Unit' (ODU), or section of the island's coastline.

ODU16 covers the area from Langstone Bridge Carpark to Langstone Bridge and includes the northern part of the A3023 access road onto the island. The Strategy

identifies that without defences in place the flood cell could merge with adjacent flood cells to the east and west during larger return period events. In this scenario, safe access and egress on to and off the island would be severely compromised.

The strategic intent for this area is to protect and maintain the viability of the A3023 into the future, as critical road infrastructure on the island, with the preferred option being to construct new defences which keep pace with sea level rise. A study to investigate this further is identified in the short-term action plan for 2029. However, the Hayling Island Coastal Management Strategy also clearly highlights that the implementation of this option is dependent on funding availability, which is not guaranteed. At the present time, no funding has been identified to progress any defence works to protect the A3023 south of the bridge (NB a scheme has been developed and is fully funded to protect properties and the A3023 north of the bridge and is currently subject to a planning application).

We advise that the LPA should formally consider the emergency planning and rescue implications of new development in making their decision in light of the issues highlighted by the Hayling Island Coastal Management Strategy.

End Note

Coastal Partners makes comments only in relation to tidal flooding, and it is for the LPA to consider all other forms of flood risk as required by the NPPF and PPG. Equally, it is for the LPA to satisfy themselves that any NPPF / PPG / local policy requirements for passing the sequential and exception tests have been met for all forms of flooding, including tidal risk.



Nicola Reid BSc (Hons) PGDip TP

Principal Coastal Planner - Team Leader (Planning, EIA & Heritage)

Coastal Partners - Havant Borough Council, Public Service Plaza, Havant, PO9 2AX