

Dear Robert,

Thank you for consulting Environmental Health (pollution) regarding the above discharge of condition application.

Condition 12 - Construction Environmental Management Plan

I have reviewed the document entitled 'Construction and Environment Management Plan' (dated June 2025) [prepared by Waterman Infrastructure & Environment Ltd] and I am satisfied that the requirements of the condition have broadly been met, however the following information is requested.

Construction hours

It is requested that the Construction and Environment Management Plan (CEMP) includes that no plant shall be operated before 8am.

Dust control measures

Details of dust control measures are broadly satisfactory, however it is requested that the following control measures are included.

The site manager / responsible person shall carry out daily visual inspections for dust emissions from site crossing the boundary and maintains a log to be made available to the local authority upon request.

Details of an adequate water supply to be used for water suppression.

Speed limits for surfaced and unsurfaced roads on site [recommend 15mph for surfaced and 10mph for non-surfaced].

Details of storage arrangements for sands and aggregates - it is anticipated that potentially dust emitting materials are stored in bunded areas or in silos.

Noise control measures

I am satisfied that details of noise control measures are broadly satisfactory. Section 5.11 details that noise monitoring shall be undertaken where necessary, details of proposed noise monitoring locations and monitoring methodology are requested - it is

anticipated that monitoring methodology shall be in accordance with a methodology detailed in annex E of BS5228-1:2009.

Site map

A site map is requested detailing areas for materials storage, loading / unloading, compound, contractor parking, plant/equipment storage, wheel wash.

It is recommended the applicant be required to provide the above information for approval to discharge the condition.

Kind regards

Craig Milligan

Environmental Protection

Environmental Health

Public Service Plaza

Civic Centre Rd

Havant

PO9 2AX

Telephone:

Email: ehealth@havant.gov.uk