

Subject: RE: Consultation Request for APP/25/00639 Proposed Development site (former Electricity Board site), Bartons Road, Havant

Afternoon David

Building Control would make the following observations:

1. No drawing showing Fire Authority or Refuse vehicle turning provisions along with max distance to further point of a dwelling (AD B / H)
2. Location of solid bin waste storage not indicated from what I can find (AD H)
3. Foul and surface public sewers run across this site SWS should be consulted (AD H)

Regards

Colin Adams
RBI Class 2F
BSc (Hons) MRICS FRACS

Senior Building Control Surveyor T: 02392 446574 or Admin 02392 446571
Havant Borough Council, Public Service Plaza, Havant, PO9 2AX