



Havant Borough Council
Civil Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/25/00678

Our ref
DSA000047847

Date
30th of September 2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Proposed 2 story side extension and single-storey rear extension.
Site: 14 Elm Close Estate, Hayling Island, PO11 9AT.

Thank you for your correspondence, please see our comments below regarding the above application.

Connection to public sewer

Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer. To make an application visit Southern Water's Get Connected service: <https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available on our website via the following link: <https://www.southernwater.co.uk/developing-building/connection-charging-arrangements>

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to and approved in writing by the Local Planning Authority in consultation with Southern Water.

Proposed soakaways

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development. No new soakaways should be located within 5 metres of a public or adoptable gravity sewer, rising main or water main.

No Soakaways should be connected to the public surface water sewer.



For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team

southernwater.co.uk/developing-building/planning-your-development