



Outlook

Re: APP/25/00579 - 2 Christopher Way

From Danny Manns [REDACTED]**Date** Wed 2025-10-15 5:53 PM**To** Riley, Robert <Robert.Riley@havant.gov.uk>

CAUTION: This email came from outside of the council - only open links and attachments that you're expecting.

12.5mm spa solar reflective chippings to achieve aa designated fire rating for surface spread of flame bedded in bitumen on three layer felt to BS 747 on 22mm exterior grade plywood.

Please also see detail 14 on the plans as this details the material.

Kind regards

Danny Manns [REDACTED]

DM Designs