

From: Thomas, Darren [REDACTED]
Sent: Wednesday, April 24, 2024 7:49 AM
To: Toole, Joseph [REDACTED]
Subject: RE: APP/24/00115 - 36 Summerhill Road, Waterlooville, PO8 8XE

Joseph

The plans have been amended to reduce the unprotected area due to the windows which will comply with Requirement B4.

Other issues the application needs to consider, although more relevant to the Building Regulations application, will be the means of escape from the first floor rooms and the ground floor study and the ventilation of the bathroom and shower room. The design of the windows need to provide adequate means of escape which mean a change in style to allow this.

Regards

Darren Thomas
BSc (Hons) C.Build E MCABE

Principal Building Control Surveyor | [REDACTED]
Havant Borough Council, Public Service Plaza, Havant, PO9 2AX
East Hampshire District Council

If you require a Building Control inspection and have a current Building Regulation application please phone 02392 446 571 by 4pm on the day before you want the inspection.

www.havant.gov.uk
www.facebook.com/havantboroughcouncil
www.twitter.com/havantborough

www.easthants.gov.uk
www.facebook.com/easthampshiredistrictcouncil
www.twitter.com/easthantsdc

Your privacy matters. Go to www.havant.gov.uk/privacy-policy