

AIR FLOW MEASUREMENT (FIXED SYSTEM 1 FAN ONLY)

Customer:	JCT GROUP SERVICES
Dwelling Address:	2B LONGWOOD AVENUE, COWPLAIN, HANTS. PO8 8HX
Test Date:	17 TH MAY 2023

TEST EQUIPMENT

Air flow measurement Equipment used (Please state model & type)	TESTO 417 ANENOMETER & 330X300MM FUNNEL BIS19206	
Date of UKAS calibration	01/05/2023	Certificate No: UK_37813
Model No	417	

Test Method used	Tick	Please refer to BSRIA Guidance Note for further information on method
Method 1 Unconditional method		Complete boxes (a), (b), (c), (d), (g) & (h)
Method 2 Conditional method		Complete boxes (a), (b), (c), (d), (e), (f), (g) & (h)
Method 3 Minimum benchmark method	✓	Complete boxes (a), (b), (c), (d), (g) & (h) (15 l/s = 12 l/s), (30 l/s = 24 l/s) or (60 l/s = 35 l/s)

AIR FLOW MEASUREMENTS

(a) Fan Reference	(b) Manufacturer	(c) Model	(d) Measured extract Rate (l/s)	(e) Fan correction factor	(f) Corrected Extract Rate (l/s)	(g) Design Extract Rate (l/s)	(h) Pass/Fail	(i) Reason for Failure
KITCHEN HOOD	LAMONA	N/A	82.1	N/A	NONE	60	PASS	
1 ST FL BATH	BLAUBERG		21.7	N/A	NONE	15	PASS	
GF CLOAK	BLAUBERG		22.3	N/A	NONE	15	PASS	

TEST ENGINEERS DETAILS

Name	MARK WITCHER
Company	Airtight & Noisecheck Ltd
Address	The Old Laundry, Bridge Street, Southwick, Hampshire, PO17 6DZ
Telephone	03450 666966
Email	info@airtightnoisecheck.co.uk

Notes: No correction factors provided for bathrooms or kitchen hood extractors. However, all extractors satisfy the minimum benchmark required



For further advice, please contact us on 03450 666966