

Essalih, Ikrame

From: Javed, Ghazala <GHAZALA.JAVED@tetrattech.com>
Sent: 24 July 2024 09:03
To: Essalih, Ikrame
Subject: FW: Discharge of Conditions Application APP/20/00875 at Aura House, New Road Havant

Follow Up Flag: Follow up
Flag Status: Flagged

CAUTION: This email came from outside of the council - only open links and attachments that you're expecting.

Essalih,

Hope you are well please see below –email from our noise consultant in response to your queries re: the noise report.

Should you need any further assistance please do let me know.

Kind Regards

Ghazala
[REDACTED]

From: Dave [REDACTED]
Sent: Tuesday, July 23, 2024 10:19 AM
To: Javed, Ghazala <GHAZALA.JAVED@tetrattech.com>
Cc: Gary Robinson [REDACTED]
Subject: RE: Discharge of Conditions Application APP/20/00875 at Aura House, New Road Havant

 **CAUTION:** This email originated from an external sender. Verify the source before opening links or attachments.

Ghazala,

Further to your recent communication, we believe that we have provided the information in order to discharge the Planning Condition as shown in section 9.20 in our noise assessment.

This shows that an acoustic wall vent should be installed to the rear façade with an upgraded glazing specification.

Glazing & Ventilation Assessment



PROPOSED VENTILATION AND GLAZING

6MM GLASS / 6 - 16MM AIR GAP / 4MM GLASS & TITON V75 / C75

10MM GLASS / 16MM AIR GAP / 8.8MM GLASS & GREENWOOD MA-3051

The development should be designed with a 6mm glass / 6 - 16mm air gap / 4mm glass double glazed windows and a Titon V75 / C75 as shown above in blue and a 10mm glass / 16mm air gap / 8.8mm glass & Greenwood MA-3051 wall vent as shown in red above in order to comply with the LA_{max} levels as shown in section 9.22 or similarly approved to all rooms to ensure the internal noise levels are acceptable in terms of the assessment to British Standard 8233: 2014.

I trust the above is of value and should you require anything further, then please do not hesitate to contact me.

Kind Regards

Mr Dave Stephens

www.soundadviceacoustics.co.uk

Sound Advice
ACOUSTICS LTD