

Essalih, Ikrame

From: Steve Carrington - Oander <steve.carrington@oander.co.uk>
Sent: 14 September 2023 09:00
To: Essalih, Ikrame
Cc: [REDACTED]
Subject: RE: Planning Application APP/23/00491 at Waterloo Health Centre, Dryden Close, Waterloo PO7 6AL

Categories: Agents & Consultees

CAUTION: This email came from outside of the council - only open links and attachments that you're expecting.

Good morning Mr Essalih,

Having double checked on this with the supplier I have been advised of the following;

"The proposed (inverter) location would be either in the plant room on the wall or affixed to the side of the array.

From my understanding the inverters are no louder than 40DB".

If you require anything else please let me know

Regards

Steve Carrington BEng (Hons)
Operations Director



Oander Limited | Unit 3 Hollybush Business Centre | Shipley Bridge Lane | Horley | Surrey | RH6 9TL
M: +44 (0) 7823 405810 | T: +44 (0) 1342 718 758 | E: steve.carrington@oander.co.uk | www.oander.co.uk

Please consider the environment - do you really need to print this e-mail?

This email is confidential and is intended solely for the use of the individual to whom it is addressed. Any views or opinions expressed are solely those of the author and do not necessarily represent those of Oander Limited. If you are not the intended recipient of this email, please inform the sender immediately and delete this email from your system. If that is the case, you must not use, copy or disclose any part of this email for any purpose.