

Houghton, Michelle

From: Karpezo, Marta <Marta.Karpezo@southernwater.co.uk>
Sent: 21 March 2019 16:35
To: [REDACTED]
Subject: RE: 4046B - LTP Building 6000

Good Afternoon Chris

Thank you for your emails.

I can confirm that the 4 meters stand off distance as applied on your drawing Entrance Section Demarcating Existing Drainage drwg number 0110 Rev A would be acceptable to us.

I would like to highlight that the exact location, size and depth of the sewer shall be determined and taken into account in further design (if not done it yet).

Kind Regards

Marta Karpezo
Technical Co-ordinator
Developer Services
Southern House, Sparrowgrove, Otterbourne, Hant SO21 2SW
Tel: 01962716278
Email: marta.karpezo@southernwater.co.uk
Web: www.southernwater.co.uk

