



Hampshire County Council

Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

Enquiries to	Vicki Westall	My reference	SWM/2018/0967
Direct Line	01962 846730	Your reference	APP/16/00774 (CDN22)
Date	1 May 2019	Email	swm.consultee@hants.gov.uk

Dear Sir/Madam,

Re: Response 1 - Erection of 147 dwellings with associated parking, access, landscaping, and surface water drainage, pumping station, sub station and signalised junction onto Havant Road (amended scheme). (Approved 29/06/2018). Request to discharge condition No/s 3, 4, 9, 12, 13, 14, 16, 17, 18, 20, 22 and 24 (15.11.2018). at Land north of Havant Road and west of Selangor Ave, Emsworth

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

Planning consent with conditions was previously given for this site and the following condition relates to that of the surface water drainage:

Condition 22:

No development shall take place until a scheme showing the offsite surface water drainage connection point has been submitted to and agreed in writing by the Local Planning Authority, in consultation with the Southern Water and/or the Highways Authority. No part of the development shall be occupied until the approved scheme has been implemented.

Reason: Without the provision of an appropriate surface water connection point the development cannot be appropriately mitigated and having due

Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI

regard to policies and proposals CS16 and DM10 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.

The County Council has reviewed the following documents relating to the above application:

- Flood Risk Assessment Report including appendices
- Ground Investigation Report
- Drainage Layout (CLXX(52)2001)- Sheet 1
- Drainage Layout (CLXX(52)2002)- Sheet 2
- Drainage Layout- Plot Drainage (CLXX(52)2101)- Sheet 1
- Drainage Layout- Plot Drainage (CLXX(52)2102)- Sheet 2
- Drainage Layout- Plot Drainage (CLXX(52)2103)- Sheet 3
- Drainage Layout- Plot Drainage (CLXX(52)2104)- Sheet 4
- Drainage Layout- Plot Drainage (CLXX(52)2105)- Sheet 5
- Drainage Layout- Plot Drainage (CLXX(52)2106)- Sheet 6
- Drainage Layout- Plot Drainage (CLXX(52)2107)- Sheet 7
- Drainage Layout- Plot Drainage (CLXX(52)2108)- Sheet 8
- Roads and Sewers- Drainage Plan (CLXX(52)2201)- Sheet 1
- Roads and Sewers- Drainage Plan (CLXX(52)2202)- Sheet 2
- Roads and Sewers- Drainage Plan (CLXX(52)2203)- Sheet 3
- Roads and Sewers- Drainage Plan (CLXX(52)2204)- Sheet 4
- Roads and Sewers- Drainage Plan (CLXX(52)2205)- Sheet 5
- Roads and Sewers- Drainage Plan (CLXX(52)2206)- Sheet 6
- Roads and Sewers- Drainage Plan (CLXX(52)2207)- Sheet 7
- Roads and Sewers- Drainage Plan (CLXX(52)2208)- Sheet 8
- Engineering- Drainage Details (CLXX(52)5001)- Sheet 1
- Engineering- Drainage Details (CLXX(52)5002)- Sheet 2
- Engineering- Drainage Details (CLXX(52)5003)- Sheet 3
- Engineering- Drainage Details (CLXX(52)5004)- Sheet 4
- Engineering- Drainage Details- Surface Water Pump Station (CLXX(52)5005)- Sheet 5
- Engineering- Drainage Details- Foul Water Pump Station (CLXX(52)5006)- Sheet 6
- Engineering- Drainage Details- Surface Water Attenuation Tank (CLXX(52)5007)- Sheet 7
- CLXX(52)5301- Roads and Sewers- Drainage Details
- Adoptable Drainage Schedules

In order for us to provide a substantive response, the following information is required:

- Correspondence which confirms approval from Southern Water regarding the Section 98 as mentioned in the Flood Risk Assessment and accepting site run-off into the public sewer network.

We require this further information before we can make a decision on whether to recommend to the Local Planning Authority that planning permission is granted.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21 day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

This is our **first response** to this consultation. If the above listed material is not supplied in full, a second response will be issued requesting the outstanding information. If the relevant documentation is not supplied following the second request we will recommend that the planning application be refused on the grounds of insufficient information.

Please ensure all data is sent to us via the relevant Local Planning Authority.

For guidance on providing the correct information, we recommend you use our **Surface Water Management Pre-application service** which provides clear guidance on what is required for us to recommend that planning permission is granted and consider the works as best practise. For full details, please visit: <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning> and click on [pre-application advice request form](#).

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, Ell Court West,
The Castle, Winchester, Hampshire SO23 8UD
Web: <http://www3.hants.gov.uk/flooding/watercourses.htm>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

PLEASE NOTE: *If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link <http://www3.hants.gov.uk/flooding/hampshireflooding/watercourses.htm>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

*For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manner. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/WatercoursePreApplication>