

Essalih, Ikrame

From: Essalih, Ikrame
Sent: 22 May 2024 07:52
To: Essalih, Ikrame
Subject: FW: Planning Application APP/23/00491 at Waterlooille Health Centre, Dryden Close, Waterlooille PO7 6AL

From: James Daly [REDACTED]
Sent: Thursday, March 28, 2024 9:46 AM
To: Essalih, Ikrame <Ikrame.Essalih@havant.gov.uk>
Subject: RE: Planning Application APP/23/00491 at Waterlooille Health Centre, Dryden Close, Waterlooille PO7 6AL

CAUTION: This email came from outside of the council - only open links and attachments that you're expecting.

Hi Ikrame,

Please see below response from our technical team regarding the noise test,

"We cannot provide the frequency of the noise; this is not outlined in any SolarEdge documents or datasheets. We do have the Decibel which is < 67 dBA

Solar is silent other than the inverter. The inverter I would describe as high frequency noises. This would be from the cooling fans (comparable to noise from a computer server) and small relays clicking."

Let me know how you want to proceed.

Thanks,
James

Kind Regards

James Daly
Sales Executive



| eesgroup.co.uk | info@eesgroup.co.uk

 **energy efficient**
solutions group



Energy Efficient Solutions Group is a trading name of Smart Electronic Technologies Ltd which is a company registered in England and Wales under number 04437964 . Registered office: Unit 3 The Western Centre, Western Road, Bracknell, Berkshire RG12 1RW.

Energy Efficient Solutions Group accepts no liability for the content of this email, or for the consequences of any actions taken on the basis of the information provided, unless that information is subsequently confirmed in writing. Any views or opinions presented in this email are solely those of the author and do not necessarily represent those of the company.