

From: Evans, Laurence <Laurence.Evans@havant.gov.uk>

Sent: 15 April 2025 18:12

To: Pickup, Tina <Tina.Pickup@havant.gov.uk>; HBC Environmental Health <EHealth@havant.gov.uk>

Cc: Le-Vallee, Helen <Helen.Le-Vallee@havant.gov.uk>

Subject: RE: APP/25/00125 - First Floor 10 Mengham Road, HI

Hi Tina,

To ensure that noise and vibration from the operation of the gymnasium do not unduly impact the amenity or quality of life of nearby residential occupiers, we recommend that the following condition be imposed on any consent granted:

Condition

Appropriate mitigation measures shall be implemented, retained and maintained to control the transmission of airborne noise and structure-borne noise from the operation of the gymnasium. These measures must ensure that noise levels within any residential habitable areas do not exceed the following criteria:

Airborne Noise (e.g. music):

Noise from health and fitness activity shall not exceed curve G15 ($L_{eq,5min}$) during the daytime and curve G10 at night.

Impact Noise (e.g. weight drops):

Noise from health and fitness activity shall not exceed curve G20 ($L_{max,F}$) during the daytime and curve G15 at night.

For the purposes of this condition, “daytime” is defined as 07:00 to 23:00 hours and “night-time” as 23:00 to 07:00 hours.

Many thanks,

Laurence

Laurence Evans

Pollution Team Leader | T 023 92446045



Environmental Health, Havant Borough Council

Public Service Plaza, Civic Centre Road, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.