



t. 023 8064 4000
e. csprotection.admin@hantsfire.gov.uk
w. hantsfire.gov.uk

For the attention of Mr J Sadler

Planning
Public Service Plaza
Civic Centre Road
Havant
Hampshire
P09 2AX

Date: 31 October 2022

Enquiries To: Jonathon Lambert

Mobile Tel: 07977161905

My Reference: F6/JL/00835815

Your Reference: APP/21/01010

Dear Mr J Sadler

Town & Country Planning Act 1990
Fire and Rescue Services Act 2004
Planning Application Number: APP/21/01010
Address: Lane east of Georges Avenue, Havant

Drawings and Documents Referenced

Title	Drawing / Doc No	Revision	Date
Fire Strategy Plan	PLN-1-1108	J	21/10/2022
Site plan	PLN-1-1112	J	21/10/2022

Description of Works:

HIWFRS understands that the project involves the erection of 184 dwellings, means of access, public open space, play areas, associated infrastructure and landscaping.

I confirm that Hampshire & IOW Fire and Rescue Service (HIWFRS) has received your application, dated 27 October 2022. The inspector named above has considered the information provided and has made the following comments:

Building Regulations: Access for Firefighting

Access and facilities for Fire Service Appliances and Firefighters should be in accordance with Approved Document B5 of the current Building Regulations.

Hampshire Act 1983 Section 12 – Access for Fire Service

Access **to** the proposed site should be in accordance with Hampshire Act 1983 Sect, 12 (Access to buildings **within the site** will be dealt with as part of the building regulations application at a later stage). Access roads **to** the site should be in accordance with Approved Document B5 of the current Building Regulations.

Fire and Rescue Services Act 2004

The following recommendations are advisory only and do not form part of any current legal requirement of this Authority.

Water Supplies

Additional water supplies for fire-fighting may be necessary. You should contact the Water Management Team, Hampshire & IOW Fire and Rescue Headquarters, Leigh Road, Eastleigh, SO50 9SJ (hydrants@hantsfire.gov.uk) to discuss your proposals.

Fire Protection

HIWFRS would strongly recommend that consideration is given to installation of an Automatic Water Fire Suppression Systems (AWFSS) to promote life safety and property protection within the premises.

HIWFRS is fully committed to promoting Fire Protection Systems for both business and domestic premises. Support is offered to assist all in achieving a reduction of loss of life and the impact of fire on the wider community.

Testing of Fire Safety Systems

HIWFRS strongly recommends that, upon commissioning, all fire safety systems are fully justified, fully tested and shown to be working as designed. Thereafter, their effectiveness should be reconfirmed periodically throughout their working lifecycles.

Firefighting and the Environment

Should a serious unsuppressed fire occur on the premises, the water environment may become polluted with 'fire water run-off' that may include foam. The Service will liaise with the Environment Agency at any incident where they are in attendance and under certain circumstances, where there is a serious risk to the environment, a 'controlled burn' may take place. This of course could lead to the total loss of the building and its contents.

Premises' occupiers have a duty to prevent and mitigate damage to the water environment from 'fire water run off' and other spillages.

If have any queries concerning these matters may be directed to the inspector named above, but all correspondence should be addressed to the Chief Officer.

Please quote our reference number on all correspondence.

Yours sincerely



Neil Odin
Chief Officer