

[REDACTED]

Sent: 08 February 2021 09:13

To: Wells, Lesley <Lesley.Wells@easthants.gov.uk>

Subject: RE: APP/20/00441 - Land West of Hulbert Road, Havant

[REDACTED]

Having looked at the submitted drawings in relation to my initial response I have the following:

- We still have concerns with the impact the footway will have on the existing trees along Hulbert Road. It appears the RPA's extend into the carriageway and the excavation to construction the footway will inevitably have an impact. It would be beneficial to have the RPA's overlaid on the proposed footway and proposed access drawings. We require a mitigation strategy to ensure the character of the Hulbert Road is retained.
- Have we received any amended site plans following my initial comments in relation to the internal layout? The letter from the applicant suggests that they have made some amendments but I cannot see any revised plans.

Kind regards,

Harry Mitchell CMLI

Chartered Landscape Architect | T: 02392 446 521 | M: 0771 8125937

Civil Engineering and Landscape Team, Havant Borough Council, Public Service Plaza, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.

