

Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/18/00761
Our Ref
PLAN-024964
Date
25/10/2018

Dear Sirs,

Proposal: Installation of 2No bay carport to front of property. (Approved 19.9.18) Request to Discharge Condition No.3 (28.9.18).
Site: 27 Victoria Avenue, Hayling Island, PO11 9AJ.
APP/18/00761

Thank you for your letter of 05/10/2018.

Southern Water cannot recommend discharge of condition 3.

Drawing 0613-113 shows a 1.5m distance from the 600mm surface water sewer which is not acceptable to Southern Water.

No development or new tree planting should be located within 3.5 meters either side of the external edge of the public 600mm sewer and all existing infrastructure should be protected during the course of construction works.

Yours sincerely

A black rectangular box used to redact the signature of Claire Smith.

Claire Smith
Developer Services