



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref
APP/17/00529
Our Ref
PLAN-022482
Date
24/04/2018

Dear Sirs,

Proposal: Request to Discharge Condition 13, 15 and 18.
Site: 380 Sea Front, Hayling Island, PO11 0BD.
APP/17/00529

Thank you for your letter of 09/02/2018

Southern Water cannot recommend discharge of condition 18 as the onsite foul drainage details are not clear and final connection point for foul has not been indicated on drainage proposals.

Kindly submit a drainage layout plan clearly indicating the on-site foul drainage, and its relevant discharge point on to public sewer.

Southern Water would have no comments to make with regards to other conditions being subject of consultation.

Yours sincerely,



Developer Services