



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref
APP/18/00565
Our Ref
PLAN-023420
Date
21/08/2018

Dear Sirs,

Proposal: Formation of access road from Bartons Road to residential development site.
Site: Land South of Eastleigh House & Helmsley House, Bartons Road, Havant, PO9 5NB.
APP/18/00565

Thank you for your consultation letter of 01/08/2018.

The comments in our response dated on 02/07/2018 remain unchanged and valid.

In order to confirm the acceptability of the submitted drainage layouts, any proposals for diversion of public sewers shall be agreed and approved by Southern Water under Section 185 of the Water Industry Act.

This initial assessment does not prejudice any future assessment or commit to any adoption agreements under Section 104 of the Water Industry Act 1991. Please note that non-compliance with Sewers for Adoption standards will preclude future adoption of the foul sewerage and surface water network on site. The design of drainage should ensure that no groundwater or land drainage is to enter public sewers.

Yours sincerely

A solid black rectangular box used to redact the signature of the sender.

Marta Karpezo
Developer Services