



Department of Planning and  
Development  
Havant Borough Council  
Public Service Plaza  
Civic Centre Road  
Havant  
Hampshire  
PO9 2AX

Developer Services  
Southern Water  
Sparrowgrove House  
Sparrowgrove  
Otterbourne  
Hampshire  
SO21 2SW

Tel: 0330 303 0119

Email: [developerservices@southernwater.co.uk](mailto:developerservices@southernwater.co.uk)

Your Ref

APP/17/00369

Our Ref

PLAN-018792

Date

06/07/2017

Dear Sirs,

**Proposal: Outline planning application for the demolition of existing building and erection of a three-storey block of thirty-one flats, together with associated car and cycle parking.**

**Site: The Curlew, Petersfield Road, Havant, PO9 2HU.**

**APP/17/00369**

Thank you for your letter of 13/04/2017.

The submitted sewer protection measures as shown in drawing no. FB 5728/100 shows that building works within 3 metres of the foul sewer which is not satisfactory to Southern water.

Please note:

-No development or new tree planting should be located within 3.5 metres either side of the centreline of the 675mm foul sewer.

The comments in our response dated on 27/04/2017 remain unchanged and valid for the amended details.

Yours sincerely,



Developer Services