



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/19/00619

Our ref
PLAN-029337

Date
30/08/2019

Contact
Tel 0330 303 0119

Dear Sirs,

Proposal: Demolition of existing extension at No.39 and construction of 1No. 2 bed dwelling with parking.

Site: 39 Vian Road, Waterlooville, PO7 5TW.

Thank you for your letter dated 13/08/2019.

The proposed development layout in relation to the public critical foul sewer is acceptable to Southern Water. No further encroachment to the public sewer than what is shown on drawing Drainage Plan 18027-SK106 will be permitted.

The submitted above drawing indicates proposal for diversion of the sewer crossing the site and seemed to be public. Any public sewer diversion proposals shall be agreed and approved by Southern Water under Section 185 of the Water Industry Act before proceeding on site.

For further advice, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119), www.southernwater.co.uk or by email at developerservices@southernwater.co.uk.

Yours Sincerely



Marta Karpezo
Developer Services