

From: Dudley, Ken [REDACTED]
Sent: Monday, April 22, 2024 4:00 PM
To: Toole, Joseph <[REDACTED]>
Subject: RE: APP/23/00921 - Creek View Selsmore Avenue

CAUTION: This email came from outside of the council - only open links and attachments that you're expecting.

Hi Joseph
Further to our earlier telephone conversation.

The need for the driveway works to ensure the new works slope into the site rather than to the footway/highway as built, was raised originally by the HA.
That surfaced area will prevent spillage of surface materials from the site.
However, the works as completed do not slope into the site, but the slope outwards is minimal and with the other driveway works would in overall terms be unlikely to result in any significant increase in surface water running to the highway and on balance the Highway Authority would raise no objection.

Kind regards

Ken

Ken Dudley
Consultant Transport Planner – Highways Development Planning
Hampshire County Council
1st Floor, Ell Court West, The Castle, Winchester, SO23 8UD
[REDACTED]
Web: www.hants.gov.uk



Hampshire County Council operates a pre-application highway advice service for developers. Hampshire County Council welcomes and encourages discussions before a developer submits a planning application. Please follow this link for further information
<https://www.hants.gov.uk/transport/developers/highwaysdevelopmentplanning>