



Hampshire County Council

Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

Enquiries to	Vicki Westall	My reference	SWM/2019/1020
Direct Line	01962 846730	Your reference	APP/18/01109
Date	28 June 2019	Email	swm.consultee@hants.gov.uk

Dear Sir/Madam,

Re: Response 3 - Outline application for the redevelopment of Former Dairy Crest site for up to 78 dwellings with access off Fulflood Road. at Dairy Crest Depot, Dunsbury Way, Havant

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

The County Council has reviewed the following documents relating to the above application:

- *Flood Risk Assessment and Drainage Strategy by Ridge Property and Construction Consultants dated 12th April 2018.*
- *Proposed Drainage Strategy drawing – 1 in 30 yr + cc stored*
- *Proposed Drainage Strategy drawing – 1 in 100 yr + cc stored*
- *Southern Water Sewer Records*
- *Environmental Agency Product 4 Information*
- *Ridge Technical note and appendices date March 2019*

In order for us to provide a substantive response, the following information is still required:

Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI

- As per our letter dated May 2019. **The Information provided fails to determine the surface water strategy with regards to the outfall from the site.** Applicant to determine the surface water outfall and to provide evidence that this is agreed with the receiving body to the discharge rate of 7.4l/s as mentioned in the technical note dated March 2019.

We require this further information before we can make a decision on whether to recommend to the Local Planning Authority that planning permission is granted.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21 day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

This is our **second response** to this consultation. If the above listed material is not supplied in full, a third response will be issued recommending that planning permission be refused on the grounds of insufficient information.

Please ensure all further information is sent to us via the relevant Local Planning Authority.

For guidance on providing the correct information, we recommend you use our **Surface Water Management Pre-application service** which provides clear guidance on what is required for us to recommend that planning permission is granted and consider the works as best practise. For full details, please visit: <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning> and click on [pre-application advice request form](#).

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, Ell Court West,
The Castle, Winchester, Hampshire SO23 8UD
Web: <http://www3.hants.gov.uk/flooding/watercourses.htm>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

*PLEASE NOTE: If the proposals include works to an ordinary watercourse, under the Land drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link <http://www3.hants.gov.uk/flooding/hampshireflooding/watercourses.htm>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

***A Pre-application service for Ordinary Watercourse Consents** is available, allowing consents to go through in a smoother, often more timely manor. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/WatercoursePreApplication>