



Elvin Gomery  
Cowan Consultancy  
3 Turnberry House  
4400 Parkway  
Whiteley  
Fareham  
Hampshire  
PO15 7FJ

Your ref

Our ref

DS\_CC\_PPE-120861

Date

07 November 2020

Contact

Tel 0330 303 0119

Dear Mr Gomery,

Level 1 Capacity Check Enquiry: 10a The Pallant, Havant, Hampshire, PO9 1BE.

Further to our response letter and the further information you have submitted in relation to your historic connections and flowrates we have reviewed the information received.

The revised documents submitted indicate that the proposed surface water flows are now restricted and hence will support the system to be more efficient. Therefore, surface water may be discharged to the existing sewer, provided the rate of discharge to the sewer is no greater than existing contributing flows.

### Connecting to our network

A formal Sewer Connection (S106) application is required to be completed and approved by Southern Water Services to grant approval for a connection to the public sewerage system. When submitting a sewer connection application, please include this letter in your supporting documents. To make an application visit:

[developerservices.southernwater.co.uk/ConnectiontoPublicSewer/ApplicationForm](https://developerservices.southernwater.co.uk/ConnectiontoPublicSewer/ApplicationForm)

Should it be necessary to contact us please quote our above reference number relating to this application by email at [southernwaterplanning@southernwater.co.uk](mailto:southernwaterplanning@southernwater.co.uk)

Yours sincerely,



Joff Edevane  
Growth Planning Lead  
Business Channels