

Steve White

From: Sylvester, John [REDACTED]
Sent: 17 October 2016 09:03
To: Keith Sargent
Cc: [REDACTED]; 'simon lampard'; Steve Vaux
Subject: RE: 20496 : RE: Capacity check application for: Kingsclere Avenue, Leigh Park, Land Adjacent to Riders Junior And Infant School, Havant, Hampshire, PO9 4RY.

Hello Keith,

Thank you for your email.

With 1 l/s going to Kingsclere Avenue from some of the houses (and access road) and 5 l/s going to Dunsbury Way it should be an acceptable solution for Southern Water.

Regards

Name: John Sylvester

Title: Technical Co-ordinator

T. 0330 303 0119 |

www.southernwater.co.uk

Southern Water, Southern House, Sparrowgrove, Otterbourne, SO21 2SW

-----Original Message-----

From: Keith Sargent [mailto:[REDACTED]]
Sent: 14 October 2016 17:00
To: Sylvester, John
Cc: [REDACTED]; 'simon lampard'; Steve Vaux
Subject: 20496 : RE: Capacity check application for: Kingsclere Avenue, Leigh Park, Land Adjacent to Riders Junior And Infant School, Havant, Hampshire, PO9 4RY.

Thank you John,

This is good news as we have been struggling to derive a viable drainage scheme based on the 1l/s that was available into Kingsclere Avenue.

Presumably we could split the site, with the new site access road and some of the houses using the 1l/s into Kingsclere Avenue, and the remainder discharging into Dunsbury Way.

We will revise our scheme based on this approach and forward to you for your comments as soon as possible.

Thanks again,

Keith

visit our new website at www.rjwatkinson.co.uk
12 High Street, Lyndhurst, Hants SO43 7BD. Tel: 02380 283794. Fax: 02380 283655.

R J Watkinson & Partners Limited (Company Reg. No. 2117644) R J Watkinson Associates Limited (Company Reg. No. 2836917) Reg. Office 63/64 The Avenue, Southampton SO17 1XS This message and any attachment is confidential to the named recipient. If you have received this in error please inform the sender, delete the message and accept our apologies.

R J Watkinson outgoing emails are scanned for viruses but we cannot guarantee that any document is virus free and advise you to run your own security checks before opening this message or its attachments.

-----Original Message-----

From: Sylvester, John [mailto: [REDACTED]]

Sent: 14 October 2016 15:24

To: Keith Sargent

Cc: [REDACTED]

Subject: Capacity check application for: Kingsclere Avenue, Leigh Park, Land Adjacent to Riders Junior And Infant School, Havant, Hampshire, PO9 4RY.

Keith,

Following the meeting we had for this site we asked our modellers to rerun the models based on 5 l/s of surface water discharging to 2 different manholes than the one the previous capacity check was carried out on in the local area.

The results are attached. The manhole SU71081350 in Dunsbury Way shown as 1350 on the map record represents the best option for your 5 l/s.

I will also post out the details to you.

Regards

Name: John Sylvester

Title: Technical Co-ordinator

T. 0330 303 0119 |

www.southernwater.co.uk

Southern Water, Southern House, Sparrowgrove, Otterbourne, SO21 2SW

This e-mail is intended solely for the person or organisation to which it is addressed. It may contain privileged and confidential information. If you are not the intended recipient, you are prohibited from copying, disclosing or distributing this e-mail or its contents (as it may be unlawful for you to do so) or taking any action in reliance on it.

If you receive this e-mail by mistake, please delete it then advise the sender immediately by reply e-mail to "Sylvester, John"
<John.Sylvester@southernwater.co.uk>.

Without prejudice to the above prohibition on unauthorised copying and disclosure of this e-mail or its contents, it is your responsibility to ensure that any onward transmission, opening or use of this message and any attachments will not adversely affect your or the onward recipients' systems or data. Please carry out such virus and other such checks as you consider appropriate.

An e-mail reply to this address may be subject to monitoring for operational reasons or lawful business practices

This e-mail is issued by Southern Water Services Limited, company number 2366670, registered in England and having its registered office at Southern House, Yeoman Road, Worthing, BN13 3NX, England.

In sending this e-mail the sender cannot be deemed to have specified authority and the contents of the e-mail will have no contractual effect unless (in either case) it is otherwise agreed between Southern Water Services Limited and the recipient.

This e-mail is intended solely for the person or organisation to which it is addressed. It may contain privileged and confidential information. If you are not the intended recipient, you are prohibited from copying, disclosing or distributing this e-mail or its contents (as it may be unlawful for you to do so) or taking any action in reliance on it.

If you receive this e-mail by mistake, please delete it then advise the sender immediately by reply e-mail to "Sylvester, John"
<John.Sylvester@southernwater.co.uk>.

Without prejudice to the above prohibition on unauthorised copying and disclosure of this e-mail or its contents, it is your responsibility to ensure that any onward transmission, opening or use of this message and any attachments will not adversely affect your or the onward recipients' systems or data. Please carry out such virus and other such checks as you consider appropriate.

An e-mail reply to this address may be subject to monitoring for operational reasons or lawful business practices

This e-mail is issued by Southern Water Services Limited, company number 2366670, registered in England and having its registered office at Southern House, Yeoman Road, Worthing, BN13 3NX, England.

In sending this e-mail the sender cannot be deemed to have specified authority and the contents of the e-mail will have no contractual effect unless (in either case) it is otherwise agreed between Southern Water Services Limited and the recipient.

