

Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/17/00762
Our Ref
PLAN-025216
Date
12/11/2018

Dear Sirs,

Proposal: Increase in ridge height to enable loft conversion with dormer to north elevation and windows in gable ends. Single storey extension. (Revised Application). (Approved 8.9.2017). Discharge of Condition No/s 5 and 6. (27.2.2018).
Site: 15 Waterloo Close, Waterloo, PO8 8QJ.
APP/17/00762

Thank you for your letter of 18/10/2018.

Further to your letter of 18/09/2018 and revised information provided by the applicant Southern Water would have no objections to discharge condition 6.

The proposed extension will be located within 3 m of public sewer, we will require the foundations to be laid 150mm below the invert level of sewers.

Yours sincerely

A black rectangular box used to redact the signature of Claire Smith.

Claire Smith
Developer Services