



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

APP/17/00548

Our Ref

PLAN-020452

Date

13/11/2017

Dear Sirs,

Proposal: Erection of steel portal frame building with provision for offices, trade counter, staff facilities and warehouse.

Site: 4, Hermitage Park, Harts Farm Way, Havant, PO9 1JN.

APP/17/00548

Thank you for your letter of 24/10/2017.

All our comments in our response dated 14/08/2017 remain unchanged and valid.

The application proposes development that may produce a trade effluent. No trade effluent can be discharged either directly or indirectly to any public sewer without the formal consent of Southern Water. The applicant is advised to discuss the matter further with Southern Water's Trade Effluent Inspectors. Please see: <https://www.southernwater.co.uk/trade-effluent> for further information.

The applicant should be advised that a wastewater grease trap should be provided on the kitchen waste pipe or drain installed and maintained by the owner or operator of the premises.

Yours sincerely



Developer Services

