



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref
APP/17/00530
Our Ref
PLAN-022714
Date
09/05/2018

Dear Sirs,

Proposal: Erection of 2No. 3bed detached bungalows with a detached garage for each property (Approved 08/09/2017). Request to Discharge Conditions 3, 4, 6, 9, 10 and 11 (03/04/2017).

Site: Land to the rear of 78-80 Silvester Road, Waterloooville, PO8 8TS.
APP/17/00530

Thank you for your letter of 19/04/2018.

Southern Water would recommend discharge of condition 3 relating to foul sewerage disposal. An approval for connection to the public foul sewer should be obtained under Section 106 of the Water Industry Act.

The Council's Building control officers/technical staff and the Environment Agency should be consulted regarding the discharge condition 3 for surface water disposal.

No new soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public sewer (also adoptable), rising main or water main.

Yours sincerely

A solid black rectangular box used to redact the signature of the person representing Developer Services.

Developer Services