



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/18/01125

Our ref
PLAN-035056

Date
21/09/2020

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Erection of 1No. 2bed detached chalet bungalow with associated parking and access (approved 15.1.2019). Request to Discharge Conditions 3, 4, 5, 6, 7 & 12 (01.04.2020).

Site: APP/18/01125: - 8, Westbrook Grove, Waterloooville, PO7 5HX.

Thank you for your letter dated 06/09/2020.

Southern Water shall have no objections to discharge condition 05 relating to foul drainage. An approval for the connection to the public sewer should be submitted under Section 106 of the Water Industry Act.

The Council's Building Control officers/technical staff and the Environment Agency should be consulted regarding the discharge condition 05 for surface water disposal.

Southern would have no comments with respect to other conditions.

For any further queries please contact us at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,



Jon Loevane
Growth Planning Lead
Business Channels