



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref

APP/19/00380

Our ref

PLAN-027783

Date

07/05/2019

Contact

Tel. 0330 303 0119

Email: developerservices@southernwater.co.uk

Dear Sirs,

Proposal: Retention of building to rear of main industrial building temporarily approved under Planning Permission APP/14/00912.

Site: Lewmar Marine Ltd, Southmoor Lane, Havant, PO9 1JJ.

APP/19/00380

Thank you for your letter of 15/04/2019.


Southern Water has no objections to the above proposal.

Please find attached a plan of the sewer records showing the approximate position of a public foul sewers within the site. The exact position of the public foul sewers must be determined on site by the applicant before the layout of the proposed development is finalised.

Please note:

- No construction, development or new tree planting should be located within 3 meters on each side of the external edge of the public 150mm foul sewer and 3.5 meters of the public critical 600mm foul sewer.
- No new soakaways should be located within 5m of a public sewer.
- All existing infrastructure should be protected during the course of construction works.

The applicant shall demonstrate that the required statutory standoff distances to public sewers are maintained. In order to protect drainage apparatus, Southern Water requests



that if consent is granted, a condition is attached to the planning permission. For example "The developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to protect the public sewers, prior to the commencement of the development."

Furthermore, due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk.

Yours Sincerely



Marta Karpezo
Developer Services