



Department of Planning and Development  
Havant Borough Council  
Public Service Plaza  
Civic Centre Road  
Havant  
Hampshire  
PO9 2AX

Your ref

APP/18/00695

Our ref

PLAN-028104

Date

28/05/2019

Contact

Tel 0330 303 0119

Email: [developerservices@southernwater.co.uk](mailto:developerservices@southernwater.co.uk)

Dear Sirs,

**Proposal: Demolition of existing dwelling and erection of 1No. 3 bed dwelling (Approved 11/10/2018). Request to discharge conditions 2,3,5,6 & 8 (30/01/2019). Request to Discharge Condition 4 (29/04/2019). Site: 36A Wittering Road, Hayling Island, PO11 9SP. APP/18/00695**

Thank you for your letter of 08/05/2019.

Southern Water would have no objections to recommend discharge of condition 4 relating to foul and surface water disposal. It shall be highlighted, however, that in compliance with Part H1 of Building Regulations hierarchy, the foul sewerage from the proposed dwelling shall be discharged to public foul sewer located nearby.

Yours Sincerely



Marta Karpezo  
Developer Services