



Bob Bradshaw
PMC Construction & Development Services Ltd
106
Queens Road
Portsmouth
Hampshire
PO2 7NE

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

31/03/2016

Our Ref: SWS-HANTS-S106-008031

Application to Connect to the Public Sewerage System - Section 106 Water Industry Act 1991

Location: Swiss House, 9-11 St Georges Walk, Waterloooville, Hampshire, PO7 7TU.

Dear Mr. Bradshaw,

Further to your recent application to connect to the public sewerage system at the above location, I am pleased to inform you that your proposal to connect to the foul sewers via an existing lateral and surface water sewer via a new manhole has been approved subject to the following provision:-

Connections to existing and new manholes and arrangement of pipe junctions within the manhole should be in accordance with Sewers for Adoption 7th edition and Southern Water guidance documentation.

If there is any change in the approved connection point, as above, you must provide us with your revised drawing and obtain our approval for the revision prior to the connection being made.

Please contact Andy Gayle our Assistant Project Manager for this area on 07780 493920 giving at least 2 full working days notice, in order for a mutually convenient date and time for the inspection of the works to be arranged.

If connection is to be made through the lands of another, the works may not proceed until the Landowners consent has been obtained.

In approving this application it is assumed that you have obtained any necessary Building Regulations Approval and /or Highway Authority Road Opening License.

Yours sincerely,

A black rectangular box redacting the signature of the Developer Services representative.

Developer Services