



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/18/00931

Our ref
PLAN-029016

Date
31/07/2019

Contact
Tel 0330 303 0119

Dear Sirs,

Proposal: Erection of a 2 bedroom house on land to the north of 42 Lombardy Rise, Waterloooville, PO7 8EB; including access and landscaping (Approved 06/12/18). Request to Discharge Conditions 2, 3, 4, 5, 6 and 7 ((18/04/19).

Site: APP/18/00931:- Land Adj to 42 Lombardy Rise, Waterloooville, PO7 8EB.

Thank you for your letter of 27/06/2019.

The submitted proposed drainage detail(000000-01P3) is satisfactory to Southern Water. An approval for the connection should be submitted under a section 106 connection application.

The public surface water sewer diversion proposals currently being dealt under our reference SWS.S185.002437 need to be agreed and approved by southern Water under Section 185 of the Water Industry Act before proceeding with works on site.

Southern Water would have no comments to make with regards to other conditions being subject of consultation.

For any queries please contact us at developerservices@southernwater.co.uk

Yours sincerely



Claire Smith
Developer Services

Southern Water Developer Services, Sparrowgrove House, Sparrowgrove, Otterbourne, Winchester, Hampshire, SO21 2SW
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670