



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref

APP/19/00456

Our ref

PLAN-028143

Date

28/05/2019

Contact

Tel 0330 303 0119

Email: developerservices@southernwater.co.uk

Dear Sirs,

Proposal: New extension comprising a larger auditorium with creche and improved toilet facilities. Internal alterations and new side doors to the existing church.
Site: Bethnal Evangelical Church, 441 Dunsbury Way, Havant, PO9 5BD.
APP/19/00456

Thank you for your letter of 09/05/2019.

Southern Water would have no objections to the above proposal.

Southern Water requires a formal application for connections to the public foul and surface water sewers to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructure-charges>.


It is the responsibility of the developer to make suitable provision for the disposal of surface water. Part H3 of the Building Regulations prioritises the means of surface water disposal in the order:

- a Adequate soakaway or infiltration system

- 
- b Water course
 - c Where neither of the above is practicable sewer

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site. The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk.

Yours Sincerely



Marta Karpezo
Developer Services