



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref

APP/17/00529

Our Ref

PLAN-021846

Date

01/03/2018

Dear Sirs,

Proposal: Erection of 13 residential apartments including parking and landscaping following demolition of existing building (Approved 29/11/2017). Request to Discharge Conditions 8 and 11 (25/01/2018). Request to Discharge Conditions 4, 6, 13, 15, 16 and 18 (02.02.2018). Condition 17.

Site: 380 Sea Front, Hayling Island, PO11 0BD.

APP/17/00529

Thank you for your letter of 09/02/2018.

Southern Water would not recommend discharge of condition 17 relating to protection of public sewers. No constructions shall be allowed within the 3.5 metres stand off distance of public critical surface water sewer.

Yours sincerely



Developer Services