



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

APP/16/00081

Our Ref

PLAN-017634

Date

30/03/2017

Dear Sirs,

Proposal: Construction of 1No. 2 bed detached chalet style dwelling (Resubmission)(approved 22/03/2016). Request to Discharge Conditions 4, 5, 6, 7, 8, 9, 10 and 11 (18/10/2016). Withdrawal of application to discharge conditions 6, 7, 8 and 9 (12/12/2016). Request to Discharge Condition No's. 6,7,8, and 9 (24.02.17).

Site: Land rear of 3 Queens Road, Waterloooville, PO7 7SB.

APP/16/00081

Thank you for your letter of 10/03/2017.

Southern Water would not recommend discharge of condition 6 relating to foul and surface water drainage. The proposals indicate discharge of surface water run off into public foul network, which is not acceptable to Southern Water. The disposal of surface water run off should be in accordance with Part H3 of Building Regulations hierarchy.

Southern Water would have no comments to make with regards to other conditions being subject of consultation.

Yours sincerely



Developer Services