



Havant Borough Council
Civil Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/25/00981

Our ref
DSA000049873

Date
19th December 2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Single Storey rear extension to kitchen and first floor extension to form new master suite with external material alterations.

Site: 13A Billett Avenue, Waterlooville, PO7 7SZ.

Thank you for your correspondence. Please see our comments below regarding the above planning consultation application.

Development Site is not within Southern Water's Supply Area

The development site is not located within Southern Water's statutory area for water supply services. Please contact Portsmouth Water who are the relevant statutory undertaker.

Existing Southern Water Assets – General within boundary but no tree, buildings, assets within standoff distance (approximate)

Please see the attached extract from Southern Water records showing the approximate position of our existing sewer and water main assets crossing/in the vicinity of the development site. The exact position of the public assets must be determined on site by the applicant in consultation with Southern Water before the layout of the proposed development is finalised. To get in contact to confirm the exact position of the asset please visit;

https://www.southernwater.co.uk/media/ph4fk3pe/ds-location-of-rising-mains_pb.pdf.

For information on required stand-off distances from public sewers please refer to:

<https://www.southernwater.co.uk/media/st5orjvm/stand-off-distances.pdf>

Southern Water has determined that the flow rate for the above site will remain consistent, so capacity is not an issue.

Please note surface water should not be disposed of into a public foul sewer and must comply with the Hierarchy of H3 of the Building Regulations. For more details, refer to the Drainage and Waste Disposal: Approved Document_H on the GOV.UK website. Any new connections to the public



sewerage system will require a New Sewer Connection application (also known as a Section 106) to be submitted and approved by Southern Water. Due to legislative changes effective from 1st October 2011 regarding the ownership of sewers, it is possible that some previously private sewers, now deemed public, could be crossing the above property and may not be shown on Southern Water records. Therefore, if any additional sewers are discovered during construction, an investigation will be required to determine their condition, the number of properties served, and potential access methods before any further work can proceed on site.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,
Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development