

I have reviewed the Haskoning UK Ltd. *Havant Thicket Reservoir: Cut Off Wall Works – January 2026 | Noise Modelling – Technical Note* (dated 16 December 2025). The document includes sound data for the plant to be used during the works and confirms that predicted noise levels are below the Category B night-time threshold under the ABC method (Annex E, BS 5228-1:2009+A1:2014).

On this basis, I am satisfied that the submitted information is sufficient to discharge Condition 11 – Night time works. This does not remove the requirement to comply with any other statutory controls.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,
Civic Centre Road, Havant, PO9 2AX