from Southern Water

Havant Borough Council
Civil Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/25/00745

Our ref
DSA000050087

Date
6th January 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Conversion of three-bedroom house into 2No one-bedroom flats with external staircase and associated cycle storage.
Site: 4 Anthony Way, Emsworth, PO10 7RZ

Thank you for your correspondence. Please see our comments below regarding the above planning consultation application.

Development Site is not within Southern Water's Supply Area

The development site is not located within Southern Water's statutory area for water supply services. Please contact Portsmouth Water who are the relevant statutory undertaker.

Build over – close

'The attached plan shows that the proposed development is being built over a public sewer or within 3m of a public sewer. An investigation of the sewer is required to confirm its size and depth, ascertain its condition, number of properties served and potential means of access before any decision can be made as to whether it would be acceptable for the proposed development to be built close to the sewer. If the sewer in question is found to be no greater than 225mm in diameter and no deeper than 3 meters, the development may be allowed, subject to the following conditions:

1. No construction works parallel to the sewer within 500mm (in plan).

2. Where within three metres, foundations depth to be taken down 150mm below the invert level of the sewer.

The works will be subject to approval under the 'Declaration of Works' self-certification process.

It appears that the developer is intending to build close to a public foul sewer which is crossing the site. Building over a "public sewer" is not normally permitted by Southern Water.

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

However, under certain circumstances building over a minor sewer may be allowed. The conditions and application associated with the build-over/close-to a public sewer are available at Southern Water's Get Connected service: https://developerservices.southernwater.co.uk.

Condition

In order to protect drainage apparatus, Southern Water requests that if consent is granted, the following condition is attached to the planning permission; prior to the commencement of development, the developer must advise the local authority, in consultation with Southern Water, of measures which will be undertaken to protect the public sewers.

S106 Connection application

Any new connections to the public sewerage system will require a Section 106 connection application to be submitted and approved by Southern Water Services. Please note that, where there are separate systems available Southern Water will not allow surface water to connect into the public foul sewer. If this is not possible, please provide evidence that all other options have been explored.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,
Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670