Consultations with Environmental Health - SSE Bartons Road APP/25/00639

Hi Jonathan,

Thank you for bringing this to my attention.

David - can you please include the following condition regarding noise from air sourced heat pumps.

Prior to the installation of any air source heat pump (ASHP) or other external domestic building services plant, a noise impact assessment shall be submitted to and approved in writing by the Local Planning Authority. The assessment shall be carried out in accordance with BS 4142:2014+A1:2019 and shall demonstrate that the rating level of noise emitted from the plant will not exceed the existing background sound level at any noise-sensitive receptor.

Where the assessment identifies the need for mitigation, a scheme of works shall be submitted to and approved by the Local Planning Authority. All approved mitigation measures shall be installed prior to first operation of the plant and shall be permanently retained for the lifetime of the development

Reason: in the interests of residential amenity and to ensure the details are acceptable to the Local Planning Authority

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,

Civic Centre Road, Havant, PO9 2AX

Your privacy matters. Go to www.havant.gov.uk/privacy-policy

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.