Dear Tina,

Planning Application Reference: APP/25/00990

Description: Discharge of Conditions 2, 3 and 4 of Planning Permission APP/24/00618.

Location: 21 Mengham Road, Hayling Island, PO11 9BG

The Amber Acoustics document entitled 'SOUND INSULATION ASSESSMENT | report reference: AA/25/11/CPC/21MR/SI' (dated 19th November 2025) has been reviewed.

Condition 3 - Sound insulation

The proposed Hush System HD1030 meets the sound insulation requirements of the condition with claimed performance of:

- Impact L'nT,w dB = 54,
- Airborne DnT,w dB = 58, and
- Airborne DnT,w + Ctr dB = 50

The information is sufficient to discharge condition 3.

Condition 4 - Building services plant

The applicant has confirmed removal of the building services plant. Photographic evidence demonstrating removal of all plant must be submitted to fully discharge the condition.

Kind regards,

Craig Milligan

Environmental Health Officer

Environmental Health , Havant Borough Council, Public Service Plaza,

Civic Centre Road, Havant, PO9 2AX