

Hello,

Thank you for the email received yesterday in which you notified us that you have received further information.

We have looked at the solar study of overshadowing. There are two issues:


1. In the solar study, the proposed roof ridge over the first floor extension (To the north west of the building) does not have the same dimensions or appearance as that on the roof plan in the planning application. In the latter drawing, the proposed roof ridge extends further, the gable being above the proposed west wall.

Because the proposed roof ridge in the solar study is shorter than in the planning application, the study does not give useful information.

2. The solar study gives no information about the time of year when the proposed extension will cast shade on the PV panels. This period would be between the autumn and spring equinoxes, excepting the time around the winter solstice when the sun is very low in the sky.

For the above reasons we continue to object to the planning application.

Yours sincerely,

A large black rectangular redaction box covering the signature and any accompanying text.